



Existing Liner Design Evaluation for Water Recycle Ponds

Entergy Arkansas, Inc.
White Bluff Plant
Redfield, Jefferson County, Arkansas

October 2018

*Prepared For
Entergy Arkansas, Inc.*



 10/24/18

R. Kent Nilsson, P.E.
Senior Engineer



Jason House
Project Manager

*TRC Environmental Corporation | Entergy Arkansas, Inc.
Existing Liner Design Evaluation for Water Recycle Ponds
Entergy White Bluff Plant,
Redfield, Jefferson County, Arkansas*

Table of Contents

1.	Existing Liner Conditions.....	1
2.	Certification.....	2

Section 1

Existing Liner Conditions

Entergy Arkansas, Inc. (Entergy) operates the White Bluff Steam Electric Station (Plant), located at 1100 White Bluff Road, Redfield, AR 72132. This Plant operates two Water Recycle Ponds: A and B (Ponds), as part of its process water system for bottom ash transport. Pursuant to United States Environmental Protection Agency (USEPA) Disposal of Coal Combustion Residuals (CCR) From Electric Utilities Final Rule (CCR Rule) Section 40 CFR § 257.71, TRC has reviewed design drawings for the construction of the ponds to evaluate whether the constructed liner system meets the requirements for existing ponds.

The existing Ponds do not contain the liner system required by 40 CFR § 257.71; therefore, the ponds are considered unlined and are subject to the requirements of 40 CFR § 257.101(a).

Section 2 Certification

I, the undersigned Arkansas Professional Engineer, hereby certify that I am familiar with the technical requirements of 40 CFR § 257.71. I also certify that it is my professional opinion that, to the best of my knowledge, information, and belief, that this evaluation is accurate and that the existing liner design presented in the design and as-built documents does not meet the technical requirements of 40 CFR § 257.71.

For the purpose of this document, "certify" and "certification" shall be interpreted and construed to be a "statement of professional opinion". The certification is understood and intended to be an expression of my professional opinion as an Arkansas Licensed Professional Engineer, based upon knowledge, information, and belief. The statement(s) of professional opinion are not and shall not be interpreted or construed to be a guarantee or a warranty of the closure activities.



R. Kent Nilsson

9136

Printed Name of Professional Engineer

State of Arkansas License Number

10/24/18

Signature of Professional Engineer

Date